

**SAS Superstructure**

Location: 04-SF-80-13.2 / 13.9

Client Name: CalTrans

Run date 21-Nov-14

Time 2:07 PM

**Daily Diary Report by Bid Item**

Contract No.: 04-0120F4

Diary #: 337 Const Calendar Day: 608 Date: 09-May-2011 Monday

Inspector Name: Wilcox, Jason Title: Transportation Engineer

Inspection Type: Intermittent

Shift Hours: 07:00 am 03:30 pm Break: 00:30 Over Time: 00:00

Federal ID:

Location:

Reviewer: Jefferson, Paul Approved Date: Status: Submit

**04-0120F4  
04-SF-80-13.2/13.9  
Self-Anchored  
Suspension Bridge****Weather****Temperature** 7 AM 40 - 50 12 PM 50 - 60 4PM 50 - 60**Precipitation** **Condition** ClearWorking Day ☒ If no, explain:**Diary:**

Dispute

**General Comments**

Clear and mild

- At the end of the day Friday, TY Lin informed Bob Brignano and I through email that the holes in the Seismic Joint Channel Assembly could be 40mm in diameter. Eric Blue called this morning to inform me that he was going to send in an RFI on the matter. It came in as RFI2430R01 and Bob and I reviewed it.
- Opened the gate for Conco this morning so they could strip the forms on the walls of the CCO 140 mockup in the storage yard along Burma Rd.
- Drove around the perimeter of the storage yard to check for holes in the fence.
- Generated a response to RFI 2430R01.

